

# Cayuga County Water and Sewer Authority

7413 County House Road, Auburn, NY 13021

Telephone: (315) 252-0920

Fax: (315) 515-3026

Spring 2019

Dear Water Customer:

You will find an electronic version of the City of Auburn’s 2018 Annual Water Quality Report at [http://www.auburnny.gov/Public\\_Documents/AuburnNY\\_Uilities/water.pdf](http://www.auburnny.gov/Public_Documents/AuburnNY_Uilities/water.pdf) . The report is fairly self-explanatory. However, if you have any questions regarding the report or the data, please contact us. Also, if you’d like a hardcopy of the report sent to you, please let us know.

By law we must provide every customer the opportunity to review the Annual Water Quality Report. The City of Auburn is our provider of potable water and the annual report is based on their treatment and testing of the water that is supplied to the Authority for distribution.

We continue to do monthly coliform tests and all samples tested satisfactory. The City of Auburn also samples for all the above.

## Aurelius Water District 1A

Contaminant	Violation	Sample Date	Result	Units	MCL	MCLG	Sources in Drinking Water
Total Trihalomethanes (TTHMs – chloroform, bromodichloromethane, dibromochloromethane, and bromoform)	No	8/1/18	59	ug/l	80	n/a	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter.
Haloacetic Acids (mono-, di-, and trichloroacetic acid, and mono- and di-bromoacetic acid)	No	8/1/18	33.6	ug/l	60	n/a	By-product of drinking water disinfection needed to kill harmful organisms.
Copper	No	8/16/17	0.032 <sup>1</sup> Range 0.0043-0.041	mg/L	AL= 1.3	1.3	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives.

1 – The level presented represents the 90th percentile of the 5 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, five samples were collected at your water system and the 90th percentile value was the average of the first and second highest values (0.032 mg/l). The action level for copper was not exceeded at any of the sites tested.

We look forward to continuing to serve you as a customer of the Water Authority.

Respectfully submitted,

Cayuga County Water and Sewer Authority

Cayuga County Water and Sewer Authority is an Equal Opportunity Provider and Employer.  
Complaints of discrimination should be sent to the above address.