

***Annual Drinking Water Quality Report for 2022***  
***Pleasant Valley Mobile Home Park***  
***Abrio Drive & Ted's Way, Moravia, NY 13118***  
***Public Water Supply ID#NY0506418***

## **INTRODUCTION**

To comply with State regulations, Pleasant Valley Mobile Home Park will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Mr. Thaddeus M. Medrek, the state certified water operator, at 315-497-0181. We at park management will be happy to discuss any details of the water system with you.

## **WHERE DOES OUR WATER COME FROM?**

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our source of drinking water is the deep drilled well in front of the building at 17 Ted's Way. The water source is essentially the same as the well you might obtain water from if you owned your own home with a private water supply in the country.

The water is pumped from the well and chlorinated before it is held in storage tanks to allow contact time for the chlorine to react with any bacteria in the water. The deep well has naturally occurring sulphur compound content but this is negated by the chlorination process so that you do not normally taste or smell a rotten odor in your tap water.

The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

As mentioned before, our water is derived from one drilled well. The source water assessment has rated the well as having a high susceptibility to microbials, nitrates, halogenated solvents, and petroleum products. These ratings are due primarily to the close proximity of permitted discharge facilities (commercial facilities that discharge wastewater into the environment and are regulated by the state government), animal pastures, significant fertilizer use and/or storage, and a transportation route in relation to the well. In addition, the well draws from an unconfined aquifer with high hydraulic conductivity. Please note that, while the source water assessment rates our well as being susceptible to microbials, our water is disinfected to ensure that the finished water delivered into your home meets the New York State drinking water standards for microbial contamination.

County and state health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning, and education programs. A copy of the assessment is available for review by calling the Cayuga County Health Department at 253-1405.

### **ARE THERE CONTAMINANTS IN OUR DRINKING WATER?**

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological, synthetic organic compounds, and PFAS. The table presented depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Cayuga County Health Department at 315-253-1405.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Nitrate	No	11/17/2022	0.21	mg/L	10	10	Run off from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Sodium	No	10/28/21	17.2	mg/L	N/A	N/A	Naturally occurring.
Barium	No	2/16/2022	19.2	ug/L	2000	2000	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Total Trihalomethanes	No	8/16/2022	27.8	ug/L	N/A	80	By-product of drinking water disinfection needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter.
Chloroform	No	2/16/2022	11				
Bromodichloromethane:	No	2/16/2022	2.4				
Haloacetic Acids	No	8/16/2022	46.1	ug/L	N/A	60	By-product of drinking water disinfection needed to kill harmful organisms.
Lead	No	2015	1 Range <1-1	ug/L	0	15 <sup>2</sup>	Corrosion of household plumbing systems; Erosion of natural deposits.
Copper	No	2015	0.021 Range <0.005-0.023	mg/L	1.3	1.3 <sup>1</sup>	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives.
1,4-Dioxane	No	2/16/2022	<0.4	ug/L	0	1	Emission from waste incineration and other combustion; discharge from chemical factories.
Perfluorooctanoic Acid (PFOA)	No	2/16/2022	<2.0	ng/L	0	10	Released into the environment from widespread use in commercial and industrial applications.

1 – The level presented represents the 90th percentile of the 5 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, five samples were collected at your water system and the 90th percentile value was the average of the two highest values (0.021 mg/l). The action level for copper was not exceeded at any of the sites tested.

2 – The level presented represents the 90th percentile of the five samples collected. The action level for lead was not exceeded at any of the sites tested.

## UNREGULATED PERFLUOROALKYL SUBSTANCES

CONTAMINANT	VIOLATION (YES/NO)	DATE OF SAMPLE	LEVEL DETECTED	UNIT MEASUREMENT	MCLG OR HEALTH ADVISORY LEVEL <sup>1,2</sup>
Perfluorobutanesulfonic Acid (PFBS)	No	2/16/2022	0.00285	mg/L	0.002 mg/L
Perfluorohexanoic Acid (PFHXA)	No	2/16/2022	0.00328	mg/L	NA
Perfluorobutanoic Acid (PFBA)	No	2/16/2022	0.00282	mg/L	NA

1 USEPA Health Advisory Levels identify the concentration of a contaminant in drinking water at which adverse health effects and/or aesthetic effects are not anticipated to occur over specific exposure durations. Health Advisory Levels are not to be construed as legally enforceable federal standards and are subject to change as new information becomes available.

2 All perfluoroalkyl substances, besides PFOA and PFOS, are considered Unspecified Organic Contaminants (UOC) which have an MCL = 0.05 mg/L.

For additional information on PFOA-PFOS-genx chemicals : <https://www.epa.gov/sdwa/questions-and-answers-drinking-water-health-advisories-pfoa-pfos-genx-chemicals-and-pfbs>

### Definitions:

**Maximum Contaminant Level (MCL)**: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

**Maximum Contaminant Level Goal (MCLG)**: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)**: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)**: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Action Level (AL)**: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)**: A required process intended to reduce the level of a contaminant in drinking water.

**Non-Detects (ND)**: Laboratory analysis indicates that the constituent is not present.

**Milligrams per liter (mg/l)**: Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

**Micrograms per liter (ug/l)**: Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

## WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. Pleasant Valley Mobile Home Park is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

## **IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

During 2022, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

## **DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium*, *Giardia* and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791)

## **WHY SAVE WATER AND HOW TO AVOID WASTING IT?**

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

## **CLOSING**

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.