
Annual Drinking Water Quality Report for 2020

Town of Sennett

6931 Cherry Street, Auburn, NY 13021

Public Water Supply ID# (NY0511741)

INTRODUCTION

To comply with State regulations, the **Town of Sennett**, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact **Ron Schalck, District Superintendent, at (315) 253-3712 ext. #7**. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled town board meetings. The meetings are held on the **third Thursday of each month at 7:00 pm at the Town Hall located at 6931 Cherry St., Auburn, NY 13021**.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Departments and the FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source is Owasco Lake. The Town of Sennett is supplied with water from the City of Auburn. The City of Auburn owns and operates two Water Filtration Plants located in the City of Auburn on the corner of Swift St. and Pulsifer Drive. After being filtered the water is disinfected with Sodium Hypochlorite Solution before entering the distribution system. The water enters the Town of Sennett distribution system at the city line in two locations one at Franklin St. which serves districts 2 & 6 and is then pumped to a 388,000 gallon storage tank off of Pine Ridge Rd. The other location is on Grant Ave. which serves districts 1 & 3 then on to be sold to the Village of Weedsport.

Facts and Figures

The Town of Sennett serves approximately 2100 people through 770 service connections and we also distribute water to the Village of Weedsport. The Town of Sennett purchased 119,171,360 gallons of water in 2020. 49,493,664 gallons of that was sold to the village of Weedsport. The Town of Sennett had 14,888,612 gallons of unaccounted water loss due to flushing, leaks and fire fighting. All customers are billed quarterly with a minimum charge of \$52.50 for the first 7500 gallons of water and \$7.00 per thousand gallons thereafter.

A complete copy of the City of Auburn 2020 AWQR is on file at the Town of Sennett Town Hall for the public to view or http://www.auburnny.gov/Public_Documents/AuburnNY_Uilities/Water.pdf

Overview and Highlights:

The town is still working on the plans for the capital improvement project for water districts 1 & 3 in which we were awarded a grant of \$1,781,400 that is 60% of the cost to replace the water storage tank on Grant Avenue, replacing aging water mains and install some new water mains. This will provide better fire protection and more flexibility while maintaining our water system. Hydrant flushing is done in all areas of the water system in spring and fall other problem areas are done more often to remove dirt and particles out of the water mains, this also helps maintain a higher chlorine residual within the water mains. We were notified that our water meters have been recalled for warranty of the batteries which had a 10year warranty. The meter still registers water usage but can't transmit the reading to our laptop as we drive by your house. We ask for your help in getting these installed by contacting us at 315 253-3712x 7 to schedule to have the meter replaced. The Town has a self serve bulk water filling station at 6931 Cherry St. that is open to the public.

SOURCE WATER ASSESSMENT SUMMARY

The NYS Department of Health has completed a source water assessment for the City of Auburn, based on available information. Possible and actual threats to this drinking water source were evaluated. This source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to lakes. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is or will become contaminated. **(See the section of this document are there contaminants in our drinking water? for a list of the contaminants that have been detected in the drinking water.)**

The source water assessments are intended to provide managers with additional information for protecting source waters into the future. As mentioned before, our water is derived primarily from Owasco Lake. The source water assessment has rated this source as having an elevated susceptibility to protozoa and phosphorus due to the amount of agricultural lands in the assessment area and the quantity of wastewater discharged from municipal wastewater treatment plants to surface water. In addition, this source water assessment rated Owasco Lake as having an elevated susceptibility to pesticide contamination due to the amount of agricultural lands.

County and state health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning, and education programs. A copy of the complete assessment is available for review by calling the **Cayuga County Health Department at (315) 253-1405**.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. These contaminants include: total coliform, turbidity, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. **More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Cayuga County Health Department at (315) 253-1405.**

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
PHYSICAL Turbidity	No	5 days per week	0.09 Avg. Range 0.04-0.85	NTU	N/A	5.0 distribution system	Soil Runoff/Natural Lake Turnover
PHYSICAL Turbidity	No	7 days per week	0.036 Avg. Range 0.01-0.19	NTU	N/A	0.3-1.0 MCL filter performance	Soil Runoff/Natural Lake Turnover
INORGANICS							
Barium	No	3/18/20	0.021	PPM	2	2	Erosion of natural deposits
Chloride	No	3/23/17	24	PPM	N/A	250	Naturally occurring
Chromium	No	3/18/20	0.0037	PPM	N/A	0.1	Erosion of natural deposits
Cyanide	No	2/20/19	0.013	PPM	N/A	0.2	Erosion of natural deposits
Nickel	No	3/18/20	0.00021	PPM	N/A	0.1	Erosion of natural deposits
Sulfate	No	3/23/17	12	PPM	N/A	250	Naturally occurring
Sodium	No	3/18/20	18	PPM	N/A	No limit	Naturally occurring
Nitrate	No	2/20/20 5/28/20 8/20/20 11/18/20	1.058Avg. Range 1-1.2	PPM	10	10.0 MCL	Erosion of natural deposits.

ORGANICS Trihalomethanes, Total	No	2/11/20 5/13/20 8/11/20 11/10/20	Avg. 64.4 ⁵ Range 36.8-61.7	PPB	80	80 MCL	Contained in chlorinated water
HAA5	No	2/11/20 5/13/20 8/11/20 11/10/20	Avg. 26.875 Range 14.0-32.0	PPB	60	60	Contained in chlorinated water.
Lead ²	No	2020	AL=3.2 Range <1.0-4.2	PPB	0	15 PPB	Contained in finished water, an artifact of old piping and lead soldered joints.
Copper ¹	No	2020	AL=0.077 Range 0.0085-0.31	ppm	1.3	1.3 Mg/l	Corrosion of household plumbing system
Contaminants Radioactive							
Gross Alpha	No	4/16/15	7.15	pCi/L	0	15 pCi/L	Contained in soil or sedimentary rock formations
Gross Beta	No	4/16/15	ND	pCi/L	0	4 pCi/L	Contained in soil or sedimentary rock formations
Combined Radium 226/228	No	4/16/15	ND	pCi/L	0	5 pCi/L	Contained in soil or sedimentary rock formations
Unregulated Contaminants							
Chromium	No	3/18/15 6/18/15	0.29, 0.29 0.095, 0.17	ppb	N/A	N/A	Naturally occurring element; used in making steel and other alloys; chromium -3or-6 forms are used for chrome plating, dyes and pigments, leather tanning, and wood preservation
Strontium	No	3/18/15 6/18/15 12/17/15	84.1, 86.6 81.9, 80.5 85.5, 82.3	ppb	N/A	N/A	Naturally occurring element; historically, commercial use of strontium has been in the faceplate glass of cathode ray tube televisions to block x-ray emissions
Hexavalent Chromium	No	3/18/15 6/18/15 12/17/15	0.033 0.048, 0.030 0.043, 0.031	ppb	N/A	N/A	Naturally occurring element; used in making steel and other alloys; chromium -3or-6 forms are used for chrome plating, dyes and pigments, leather tanning, and wood preservation
Vanadium	No	6/18/15	0.12, 0.11	ppb	N/A	N/A	Naturally-occurring elemental metal; used as vanadium pentoxide which is a chemical intermediate and a catalyst

Chlorate	No	12/17/15	180,160	ppb	N/A	N/A	Agricultural defoliant or desiccant: disinfection by product; and used in production of chlorine dioxide
Bromide	NO	7/2/18 10/2/18	15 15	ppb	N/A	N/A	Naturally occurring
TOC	NO	1/15/20 2/19/20	1.4 1.4	ppm	N/A	N/A	Erosion of natural deposits
Manganese	NO	7/2/18 10/2/18	0.86 1.7	ppb	N/A	N/A	Naturally occurring
Haloacetic Acids, (HAA9)	NO	7/05/18 10/02/18	33.2 19.3	ppb	N/A	N/A	Contained in Chlorinated Water.
Haloacetic Acids, (HAA6Br)	NO	7/05/18	4.9	ppb	N/A	N/A	Contained in Chlorinated Water.
1,4-Dioxane	NO	10/6/20	<0.0400	ppb	N/A	N/A	Released into the environment from commercial and industrial sources and is associated with inactive and hazardous waste sites
PFOA	NO	10/6/20	<2.0	ppt	N/A	N/A	Released into the environment from widespread use in commercial and industrial applications.
PFOA	NO	10/6/20	<20.	ppt	N/A	N/A	Released into the environment from widespread use in commercial and industrial applications.
Cyanotoxin							
Microcystin Finished Water	No	8/11/20-11/2/20 30 samples	All <0.3	ppb	0	N/A ⁴	Naturally occurring due to harmful algae blooms/cyanobacteria
Microcystin Raw Water	N/A	8/11/20-11/2/20 30 samples	Range <0.3-3.07	ppb	N/A	N/A	Naturally occurring due to algae blooms/cyanobacteria

Notes:

1. – The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 10 samples were collected at your water system and the 90th percentile value was the 9th highest value, 0.077 mg/L. The action level for copper was not exceeded at any of the sites tested.
2. – The level presented represents the 90th percentile of the 10 samples collected. The action level for lead was not exceeded at any one of the 10 sites.
3. This level presents the annual quarterly average calculated from data collected.
4. The United States Environmental Protection Agency 10day health advisory level for microcystin is 0.3 ppb for children less than or equal to 5 years of age and vulnerable populations; and 1.6 ppb for all other people.
5. This level represents the highest running annual average calculated from data collected during the calendar year 2020, and the range of detected values at 2 sample sites.

Definitions:

- Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.
- Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. The Town of Sennett is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2020, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the **Safe Drinking Water Hotline (800-426-4791)**.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- Saving water saves energy and some of the costs associated with both of these necessities of life;
- Saving water reduces the cost of energy required to pump water and the need to construct costly pumping systems and water towers
- Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- Use clothes washers with only full loads.
- Turn off the tap when brushing your teeth.
- Keep a pitcher of water in your refrigerator instead of running tap until its cold for drinking.
- Consider updating older water using fixtures this could save 1,000s of gallons of water per year.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- Use your water meter to detect hidden leaks. Turn off all taps and water using appliances and then check the meter in 15 minutes. If it has moved you have a leak.
- Check outside faucets with hoses attached and turn water off at faucet don't rely on a spray nozzle to stop the water. Remove hoses from faucets for the winter months to avoid hoses and nozzle from splitting and leaking.

Dispose of Harmful Materials Properly There are few options for disposing of hazardous products used in our homes but dumping them on the ground or down the drain is not an option. If dumped on the ground they can contaminate ground water as well as make their way into lakes, rivers and streams. Septic systems and sewers cannot treat these products as they can kill helpful bacteria that these systems rely on to break down waste and can cause failure to these systems. Urge community officials to sponsor a household hazardous waste collection day for proper disposal of hazardous products if not already established.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. **Please call our office if you have questions at (315) 253-3712 ext #7.**

This report was prepared by Ron Schalck with assistance of the Cayuga County Department of Health.

This report is posted on the Town of Sennett website at <https://www.cayugacounty.us/848/Sennett-Town>